



## DESIGNER SOLICITATION / REQUEST FOR PROPOSAL

### **RESPONSES TO QUESTIONS ASKED**

Updated: February 15, 2017

From: Dr. Wilson Lacy, Ex. Director of Operations

Project: Re-Roofing E. E. Miller Elementary School (All)  
Year Round Calendar

Services Needed: Basic Re-Roofing design services through construction  
phases.

Responses Due: 5:00 p.m., February 27, 2017

---

Question: Do you require the fee proposal to be submitted with the letter of interest as stated?

Answer: No.

Question: In developing your budget did you do a moisture detection survey to determine how much of the insulation may be wet?

Answer: No, but a percentage was estimated. A survey is underway and should be complete before design starts.

Question: Is the meeting mandatory for selection?

Answer: No.

Question: Is the meeting this Thursday at 11:00am at the school or the Operations Center?

Answer: At the School.

Clarification: The existing roof structural has built-in slope. The tapered insulation system stated in the Project Description is more of a cricket system than a tapered system.