



**ADDENDUM #2:**

DATE: April 21, 2017

JOB: EE Miller Elementary School Partial Roofing Replacement; APN 1703

OWNER: Cumberland County Board of Education

ARCHITECT: Gordon Johnson Architecture

---

The following items or modifications to the original Plans and Specifications shall be included as part of the contract work. All General Conditions, Supplemental General Conditions, or Special Conditions shall remain as originally specified unless otherwise noted herein.

Respective Bidders shall include the provisions of this Addendum in their proposal and shall make a notation in the proposal that these provisions have been included.

---

**ADDENDUM #1**

- 1) Change Architectural Drawings Item #3 note referring to the removal of stone aggregate coating to "remove loose stone aggregate coating via broom or vacuum. Embedded stone shall remain." No spudding is required.

End of Addendum #2