



Project: 2018 Gymnasium Floor Refinishing – Labor and Materials to Screen and Re-coat Gymnasium Floors

**Addendum No. One
Multiple Schools**

Date: March 22, 2018

**Owner: Cumberland County Schools
801 Gillespie Street
Fayetteville, N.C. 28306**

**Bid Date: March 29, 2018
Bid Time: 2:00 p.m.**

The following changes, additions and clarifications are made to the General Conditions and Specifications for the above referenced project. **Number of pages (1)**

Pre-Bid Conference Comments:

1. Owner will sign an E-589CI – “Affidavit of Capital Improvement” in order to waive requirement to charge sales tax on labor. Therefore, only sales tax on materials shall be included in the bid.
2. Water-based finishes must be a minimum of two coats.
3. Oil-based finishes may contain a minimum of 43% solids on the first coat and a 50% minimum solids on the second coat.
4. Clarification – only the bid form and bid worksheets need to be submitted for the bid (total of 4 pages).

END OF ADDENDUM NO. 1