

PROJECT: Pauline Jones School
225 "B" Street
Fayetteville, NC 28301

ADDENDUM 01
DATE: 04-02-19

OWNER: Cumberland County schools

BID DATE: 04-17-19
TIME: 11:00am

VIA: EMAIL TO ALL BIDDERS

ARCHITECT: THOMAS GOETZ (910-485-3000) t.goetz.architect@gmail.com

This Addendum is issued prior to receipt of the bids and shall and does hereby become a part of the drawings, specifications and project manual for the project. All principal contractors shall be responsible for seeing that their subcontractors are properly appraised of the contents of this addendum. All information in the addendum shall supersede and take precedence over any conflicting information in the original drawings, specifications and project manual.

All contractors shall acknowledge receipt of the addendum.

The following changes, additions and clarifications are made to the drawings and project manual for the above referenced project. 1 page plus 6 Electronic Drawings (by email)

GENERAL / PROJECT MANUAL

01 – Here is a summary of the changes and attached are the revised Mechanical & Electrical plans:

- A. Revised location of thermostats for new units to be located on infill panel and not mounted on interior classroom wall.
- B. Changed air distribution for entry corridor to use lay-in ceiling.
- C. Changed air distribution in GUI from spiral duct to fabric duct.
- D. Modified air distribution in Multi-Purpose as part of Alternate Bid to utilize existing openings.
- E. RTU-1,2, and 3 need to be protected by fencing complete with top to prevent theft.
- F. Electrical drawings revised to mount distribution panels outside and rework feeders to Bard units. See E102.



END OF ADDENDUM NO. 01