

**PROJECT: Pauline Jones School**  
225 "B" Street  
Fayetteville, NC 28301

**ADDENDUM 03**  
**DATE: 04-12-19**

**OWNER: Cumberland County Schools**

**BID DATE: 04-17-19**  
**TIME: 11:00am**

VIA: EMAIL TO ALL BIDDERS

**ARCHITECT:** THOMAS GOETZ (910-485-3000) [t.goetz.architect@gmail.com](mailto:t.goetz.architect@gmail.com)

This Addendum is issued prior to receipt of the bids and shall and does hereby become a part of the drawings, specifications and project manual for the project. All principal contractors shall be responsible for seeing that their subcontractors are properly appraised of the contents of this addendum. All information in the addendum shall supersede and take precedence over any conflicting information in the original drawings, specifications and project manual.

All contractors shall acknowledge receipt of the addendum.

The following changes, additions and clarifications are made to the drawings and project manual for the above referenced project. 1 page + Revised Bid Proposal 00300

#### **GENERAL / PROJECT MANUAL**

1. Provide alternate bid to remove existing HVAC equipment and air distribution serving the Multi-Propose area. Provide new equipment, air distribution and wiring as shown on mechanical and electrical plans. See attached revised Bid Proposal 00300 to include Alternate 01.
2. Note approved alternative manufacturers for electrical gear are GE, Siemens, and Eaton.
3. Provide a ceiling mounted carbon monoxide detector with integral sounder base in each classroom served by the gas fired AC units. This will be the following rooms:
  - a. GCR 13, 15, 16, 17, 18, 19, 20.
  - b. Office GU-1
  - c. GCR 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12
  - d. Provide 2 carbon monoxide detectors with sounder bases in the ceiling of the Multi-Purpose room.

All carbon monoxide sensors shall be provided and installed by Simplex and be compatible with the existing Simplex 4100 panel. Activation of any carbon monoxide detector shall activate the alarm in the sounder base for that unit and sound a supervisory alarm at the main panel. Provide all wiring and components as required. All system programming shall be by Simplex.



**END OF ADDENDUM NO. 03**